## **Report of Analysis**

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

**Sample Date:** 8/28/2019 12:15 PM **Receipt Date:** 8/28/2019 3:50 PM

**Report Date:** 8/29/2019

Sample Site: DISTRIBUTION SYSTEM

**Sample ID#:** 234860

**Sample Type:** Drinking Water

Sample Source: TL Sampler: PT

**PWS ID:** CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Biological Coliform Bacteria e Coli Bacteria	absent absent	none none	SM9223B-22 SM9223B-22	0 0	8/28/2019 8/28/2019	KH KH
Inorganic Compounds Chlorine, residual	ND	mg/L	M4500CLG-2/.	0.05	8/28/2019	КН

ND = Not Detected
\* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.