

**ADDENDUM NO. 1**  
**December 4, 2019**

**PIPING EXPANSION JOINTS-BUILDING P (GHS)OPENING**  
**DATE: 12/12/19**  
**OPENING TIME: 10:00 a. m.**  
**PROPOSAL NUMBER: 2280-19**

**This Addendum No. 1 is being issued to answer the following questions which were asked at the pre-bid walk thru:**

---


Q: For the system downtime window identified in the Bid Docs as 4/10/20 thru 4/19/20, does a fire watch need to be provided?

A: Yes, a fire watch is required for the duration that the sprinkler system is offline.

Q: Will a custodian be present during the system downtime window?

A: No. The contractor should include compensation for a custodian, at the hourly rate of 75.00, for all times that work will occur during the downtime window.

All project requirements, except for those that are specifically added or modified by this Addendum, shall remain in full effect.



Eugene H. Watts

**END OF ADDENDUM NO. 1**