56 Church Hill Road • Newtown, CT 06470 • (203) 270–9973

Report of Analysis

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

Sample Date: 2/22/2021 12:40 PM **Receipt Date:** 2/22/2021 2:50 PM

Report Date: 2/23/2021

Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 261370

Sample Type: Drinking Water

Sample Source: PS017 **Sampler:** PD

PWS ID: CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection	Analysis Date	Analyst
Physical						
Color	<5	CU	SM2120B-23	0	2/22/2021	KH
Odor	0	TON	SM2150B-23	0	2/22/2021	KH
PH	7.4	pН	SM4500HB-23	0	2/22/2021	JR
Turbidity	0.3	NTU	EPA 180.1	0.05	2/23/2021	KH

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787 NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.