



# AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

## Report of Analysis

**Name:** Parkway School  
 Greenwich Public Schools - Cordes George  
 290 Greenwich Ave  
 Greenwich, CT 06830-6521


**Sample ID#:** 235193  
**Sample Type:** Drinking Water  
**Sampler:** CV  
**PWS ID:** CT0570212

**Sample Date:** 9/5/2019 12:50 PM  
**Receipt Date:** 9/5/2019 2:35 PM  
**Report Date:** 9/6/2019  
**Sample Site:** WELL #3

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
<b>Biological</b>						
MF Coliform Bacteria	0	CFU	SM9222D-22	0	9/5/2019	KH
MF e Coli Bacteria	0	CFU	SM9222D-22	0	9/5/2019	KH
<b>Inorganic Compounds</b>						
Chlorine, residual	ND	mg/L	M4500CLG-2	0.05	9/5/2019	KH

**Comments:** Based on the bacteriological examination, according to the Federal Safe Drinking Water Act (SDWA), this water was safe for drinking purposes at the time the sample was collected.

ND = Not Detected  
 \* = Above Specified Limit

**Report Approved by:**  \_\_\_\_\_ CT Lic PH-0787 NY Lic 11706  
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.