

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School

Greenwich Public Schools - Cordes George

290 Greenwich Ave

Greenwich, CT 06830-6521

Sample Date: 10/27/2021 7:45 AM **Receipt Date:** 10/27/2021 2:00 PM

Report Date: 10/30/2021

Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 275231

Sample Type: Drinking Water

Sample Source: PS008 **Sampler:** PD

PWS ID: CT0570212

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
Metals						
Copper	0.05	mg/L	EPA 200.5	0.005	10/28/2021 16:12	TJB
Lead	ND	mg/L	EPA 200.5	0.001	10/28/2021 16:13	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787

NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.