

## **Report of Analysis**

Greenwich Public Schools - Cordes George	Sample Type:	D'1' W
	Sample Type:	Drinking Water
290 Greenwich Ave	Sample Source:	PS004
Greenwich, CT 06830-6521	Sampler:	PD
10/27/2021 7:45 AM	PWS ID:	CT0570212
10/27/2021 2:00 PM		
10/30/2021		
DISTRIBUTION SYSTEM		
	Greenwich, CT 06830-6521 0/27/2021 7:45 AM 0/27/2021 2:00 PM 0/30/2021	Greenwich, CT 06830-6521 Sampler:   0/27/2021 7:45 AM PWS ID:   0/27/2021 2:00 PM 0/30/2021

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
Metals						
Copper	0.03	mg/L	EPA 200.5	0.005	10/28/2021 16:12	TJB
Lead	< 0.001	mg/L	EPA 200.5	0.001	10/28/2021 16:12	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected \* = Above Specified Limit

Report Approved by: Lab Director

CT Lic PH-0787 NY Lic 11706

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.